

No. Fail: JBPM/IP/BKK:700-7/2/25-35 (2)
(BAHARU)

SIJIL PEPASANGAN KESELAMATAN KEBAKARAN

APPROVAL CERTIFICATE

Jabatan Bomba dan Penyelamat Malaysia
dengan ini memperakukan
Fire and Rescue Department of Malaysia
hereby certify



WALL SYSTEM

Berdasarkan Piawaian
Complying with

BS 476:PART 21:1987

Syarikat Berdaftar
Registered company

BWR TECHNOLOGY SDN BHD (881013-X)
53-1-1A & 1B, Jalan Medan PB 2B,
Seksyen 9,
43650 Bandar Baru Bangi,
Selangor DE.

Tempoh sah perakuan: **03/01/2017 hingga 02/01/2018**

(DATO' RUSMANI BIN MUHAMAD)
Penolong Ketua Pengarah
Bahagian Keselamatan Kebakaran,
b.p. Ketua Pengarah
Jabatan Bomba dan Penyelamat Malaysia.

Tarikh: 4 Januari 2017

**** Peringatan:**

Sila patuhi sepenuhnya syarat-syarat dan had kegunaan
seperti dalam Lampiran A1

No. Fail: **JBPM/IP/BKK:700-7/2/25-35 (2)**
No.Siri: **BB/WS/2269/2016**

LAMPIRAN A1

Jenis Bahan Binaan	: SOLID PANEL SYSTEM 2 JAM (LOADBEARING)
Jenama & Spesifikasi	: 'ECO STARWALL BUILDING SYSTEM' Total Thickness: 152mm
Nama & Alamat Pengeluar	: BWR TECHNOLOGY SDN BHD
Tahap Rintangan Api	: LOADBEARING CAPACITY 120 MINIT, INTEGRITY 121 MINIT & INSULATION 120 MINIT
No. Laporan ujian/Tarikh	: SIRIM 2016FE0570 (17/11/2016) & 2016CBD117 (01/11/2016)
Skim Persijilan Barangan	: -----
Had Kegunaan	: HENDAKLAH MEMATUHI SPESIFIKASI UJIAN, UBBL 1984 SERTA SYARAT-SYARAT TAMBAHAN SEPERTI DI LAMPIRAN A2 & A3.



Tempoh sah perakuan: **03/01/2017 hingga 02/01/2018**